


# SONOMA STONE 750<sup>®</sup>

REF: SonomaStone750\_No Grid\_Traffic Load\_4.3ft\_1.3m

## RETAINING WALL GRAVITY SECTION

1300mm (4.25ft) Site: Surcharge - Clays Infill: Drainage Layer



### Design Specific Geometric Information

Retaining Wall System	Sonoma Stone 750	Geogrid Type and Manufacturer	N/A
Maximum Height mm (in)	1300 (51)	Minimum Geogrid LTDS kN/m (lb/ft)	N/A
Maximum Slope Above Wall	None	Maximum Slope Below Wall	None
Max. Surcharge Above Wall kPa (lb/sq.ft)	Pedestrian Surcharge 2.4 kPa (50 lb/sq.ft)	Depth of Embedment mm (in)	186 (7)
Batter of Wall	7.12 °	Compacted Base Dimension mm (in)	1120 x 186 (44 x 7)

### Design Specific Soil Information

Description (by USCS)	Soil Region				
	Infill	Retained	Foundation	Base	Drainage
		CL Inorganic Clays Low Plasticity	CL Inorganic Clays Low Plasticity	GW Well graded, free draining Granular	GP Free draining Clear Stone (3/4")
Effective Internal Friction Angle	N/A	28 °	28 °	39 °	NR
Moist Unit Weight kN/cu.m (lb/cu.ft)	N/A	20 (127)	20 (127)	22 (140)	NR
Effective Cohesion kPa (lb/sq.ft)	N/A	NR	13 (270)	NR	NR
Soil Notes		Undisturbed dense soil or well compacted Eng. fill.	Allowable bearing cap. must exceed 50kPa (1050 psf)	Crushed Gravel (free draining) compacted to 98% SPD.	Min. 300mm (12") deep, wrapped in approved Geotextile.

NR - Not Required

#### Notes:

1. This design meets or exceeds the minimum factors of safety required by Risi Stone Systems based on the design parameters listed above. The analysis was performed as outlined in the National Concrete Masonry Association Design Manual for Segmental Retaining Walls, Third Edition. This is a typical, non site-specific Design.
2. No analysis of global stability, total or differential settlement, or seismic effects has been performed.
3. This design is only provided to illustrate the general arrangement of the SRW structure for preliminary costing and feasibility purposes only. This drawing is not for construction. A qualified Engineer must be retained to provide the Final Design prior to construction.
4. Structures such as handrails, guardrails, fences, terraces, and site conditions such as water applications, drainage and soil conditions, additional live and dead loads, etc., have significant effects on the wall design and have not been taken into account in this typical section. When accounted for in the Final Design, other conditions and elements may result in additional design measures (geogrid, drainage, etc) and cost.
5. For geogrid reinforced structures, a minimum Long Term Allowable Design Strength of 14 kN/m was assumed.

Contact your manufacturer or Risi Stone Systems for a list of approved geogrid reinforcements.



Engineering design by RisiStone Inc.

UNILOCK.COM | 1-800-UNILOCK

**UNILOCK<sup>®</sup>**  
PAVERS & WALLS